SUBJECT: DEMO & SITE CLEARANCE OF 43 PROPERTIES

BID #: CF-0110-17 **OPEN DATE:** 2017-04-05

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT: CONSTRUCTION FIXED

AGENCY: MUNICIPAL CODE

BASIS OF AWARD: BY ITEM TO THE LOWEST RESPONSIVE, RESPONSIBLE BIDDER

NUMBER OF BIDS INVITED: (7) **NUMBER RECEIVED:** (4) **OTHER** (0)

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:
Item #14 was awarded to Michael Lloyd Hauling, Inc., on 04/20/17 in the amount of $3,175.00 which included $175.00 cost of asbestos survey as required by bid specifications. The performed asbestos survey requires that an asbestos abatement be performed prior to demolition. In accordance with the specifications, the awarded contractor solicited three quotes for asbestos abatement from the following companies:

1) Bradco Environmental- $2,600.00; 2) Darcco Env - $2,800.00, and; 3) Alachua Environmental Srvs- $4,995.00

Recommend approval to increase award for Item #14 to Michael Lloyd Hauling, Inc., in the amount of $2,600.00 for the asbestos abatement. Total revised award amount for Item #14 not-to-exceed $5,775.00.

The award to be funded by account: ERCC011CP-03410 to be executed by Purchase Order/Change Order.

Attachments: Recommendation Memo, Change Order, Asbestos Report, Previous Award

ANALYST: _____ MARILYN LAIDLER **RESPECTFULLY SUBMITTED** _____ GREGORY PEASE, CHIEF PROCUREMENT DIVISION

CONCURRENCE BY: Bryan Mosier, Chief, Municipal Code Compliance

---

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)
ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING _____ MEMBERS DISAPPROVING _____ DATE: _____

_____ _____ OTHER: _____

_____ _____

_____ _____

ACTION OF AWARDING AUTHORITY DATE _____

APPROVED _____ DISAPPROVED _____

OTHER _____

SIGNATURE OF AUTHENTICATION _____

City of Jacksonville, Florida

ONE CITY. ONE JACKSONVILLE.

Lenny Curry, Mayor

Municipal Code Compliance Division
Ed Ball Building
214 N. Hogan Street, 7th Floor
Jacksonville, Florida 32202

December 20, 2017

M E M O R A N D U M

12/20/17 16:06:26
Procurement Division

TO: Gregory Pease, Division Chief
Procurement Division

FROM: Bryan Mosier, Division Chief
Municipal Code Compliance Division

RE: **Change order request for item #14 on CF-0110-17**

The survey of the condemned structure at 2280 Hilly Rd. revealed asbestos in the transite siding - gray, which must be removed prior to demolition.

I recommend approval to Michael Lloyd Hauling in the amount of $2,600.00 (reference PO 7A09617)

Contractor	Item Number	Amount
Michael Lloyd Hauling	14	$2.600.00

Funding Source: ERCC011CP /03410

BM/ds

Michael Lloyd Hauling, Inc.

1601 Rudd Road
Jacksonville, FL 32220
PH 904-759-1861

Michaellloydhauling@outlook.com

Dennis ,

I need to get a change order for the following

Address: 2280 Hilly Road
PO# - 7A09617
Original Amount: $3175.00
For: abatement
Change Order Amount: 2600.00

Neighborhoods Department
Municipal Code Compliance Division
DEC 18 2017

Thank you,
Melissa Lloyd
904-759-4684
Melissa Lloyd
Michael Lloyd Hauling Inc.

BRADCO ENVIRONMENTAL

5810 Stuart Avenue, Jacksonville FL 32254 904 334-3517

November 27, 2017

PROPOSAL

To: Michael Lloyd Hauling
1601 Rudd Road
Jacksonville, FL 32220
Attn: Michael Lloyd

RE: 2280 Hilly Road

Bradco Environmental proposes to furnish all labor, material, trucking, disposal and applicable notifications for the project listed above. This Material is friable and must be removed by a licensed Asbestos Contractor. Removal is performed by a licensed Asbestos Contractor in accordance with EPA and OSHA regulations.

- Removal of ACM siding
- Price includes trucking and disposal by EPA approved landfill facility.

Total Price $ 2600 .

Jerry F Bradley, President

PAYMENT FOR WORK PERFORMED UPON RECEIPT OF INVOICE.

ACCEPTANCE OF PROPOSAL

AUTHORIZED PARTY:_____ **DATE:** _____

THANK YOU FOR THE OPPORTUNITY TO DO BUSINESS

DARCCO
ENVIRONMENTAL, INC.

ATTN: Mr. Michael Lloyd

PROPOSAL / CONTRACT

Michael Lloyd Hauling, Inc. 1601 Rudd Road Jacksonville, Florida 32220 Phone: (904)759-4684 / Fax: 781-7670 eMail: michaellloydhauling@outlook.com	Date: 2-Nov-17	Proposal No: 17339-AB
	Job Name: **Residential**	
	Job Location: **2280 Hilly Road** **Jacksonville, Florida 32208**	

Darcco Environmental, Inc. is pleased to submit our proposal for the above mention job:

We propose to furnish all equipment, labor and materials to complete the following:

To remove and dispose of ~ 1,100 SF of asbestos containing transite siding from the exterior of the home.

Air Monitoring based upon personnel air monitoring only.
All asbestos abatement shall be performed in accordance with EPA and OSHA regulations.
All disposals shall be at an EPA approved and permitted landfill facility.
Please note we are not responsible for any paint that may be removed by tape.
We appreciate this opportunity to quote your special construction needs.

All the above work will be completed for the sum of: **$2,800.00**

TWO THOUSAND, EIGHT HUNDRED DOLLARS AND ZERO CENTS

Payment to be made as follows: Payable in full upon completion.

Jerry W. Carter

Signature: _____ (ch) **Title:** President

Print Name: Jerry W. Carter **Date:** November 02, 2017

ACCEPTANCE OF PROPOSAL

Signature: _____ **Title:** _____

Print Name: _____ **Date:** _____

PLEASE SIGN AND RETURN ONE COPY UPON EXECUTION. THIS AGREEMENT BECOMES A LEGAL AND BINDING CONTRACT. IF AN ACTION BECOMES NECESSARY TO ENFORCE THIS CONTRACT, THE OWNER WILL BE RESPONSIBLE FOR THE ATTORNEY'S FEES AND THE COURT COSTS OF THE CONTRACTOR.

Alachua Environmental Services, Inc.

Post Office Box 1208 • Glen St. Mary, FL 32040 • Phone: 904-259-6200

PROPOSAL

DATE : November 01, 2017

ATTN : Michael Lloyd Hauling, Inc.
1601 Rudd Road
Jacksonville, Florida 32220

TO : Mr. Michael Lloyd

RE : ***RESIDENCE @ 2280 HILLY ROAD***
JACKSONVILLE, FLORIDA – ASBESTOS ABATEMENT

Alachua Environmental Services, Inc. proposes to provide all labor and materials to conduct the removal and disposal of asbestos containing materials. A. E. S., Inc. will comply with all local, state and federal regulations and will dispose of waste in an approved landfill. The following notations and exclusions shall clarify our quotation:

A. E. S., INC. PROPOSES TO PROVIDE LABOR AND MATERIAL TO REMOVE AND DISPOSE OF ASBESTOS CONTAINING TRANSITE SIDING FROM THE EXTERIOR LOCATED AT 2280 HILLY ROAD; JACKSONVILLE, FLORIDA

A. E. S., INC. WILL CONDUCT WORK FOR THE SUM OF: $4,995.00

NOTES: QUOTE BASED ON REGULAR WORKING HOURS. QUOTE DOES NOT INCLUDE ANY 3RD PARTY CONSULTANT.

Alachua Environmental Services, Inc. would like to thank you for this opportunity to quote this proposal with you. Please note: If paying invoice by credit card, there will be an additional 4% added to cost. Should you have any questions regarding this proposal, please feel free to give me a call. Cell contact # 904-334-1527 / Email @ aesinc_othornton@ncfcom.net

Sincerely,
ALACHUA ENVIRONMENTAL SERVICES, INC.

Owen E. Thornton

OWEN E. THORNTON
President

OET / kc

Florida Licensed-Asbestos Business Organization: ZA0000290, FL DPBR
Florida Licensed-Asbestos Contractor: CJC1154162, FL DPBR
Florida Licensed-Mold Remediator: MRSR2584, FL DPBR

ENVIRONEERING INC.
109 AZALEA POINT DRIVE SOUTH • PONTE VEDRA BEACH • FLORIDA • 32082

October 4, 2017

Mr. Michael Lloyd
Michael Llyod Hauling, Inc.
1601 Rudd Road
Jacksonville, Florida 32220

Reference: One (1) Single Story Structure – Asbestos Demolition Survey – House
2280 Hilly Road
Jacksonville, Florida – JON 6193

Dear Mr. Llyod:

Pursuant to your request an Asbestos Demolition Survey has been performed at the above location for the purpose of identifying asbestos that needs to be removed prior to the planned demolition of the structure. The purpose of the investigation was to visually identify homogenous materials that need to have bulk samples obtained for analysis to determine the presence of Asbestos Containing Building Materials with in the structure. The scope of this survey was limited to the referenced one (1) single story structure in Jacksonville, Florida. The building was inspected for demolition. The facility has one single story structure for demolition, which is constructed with period building materials. There were five (5) suspected materials that were sampled for Polarized Light Microscopy (PLM) analysis. Based on the visual inspection, it was evident that National Emission Standard for Hazardous Air Pollutants (NESHAP) 40 CFR Part 61 regulated Asbestos Material was found to be present at the facility. The scope of work for this survey included sampling and analysis of suspect homogenous building materials. The asbestos demolition inspection process was initiated on September 30, 2017. Materials must contain greater than 1% asbestos to be regulated. The following recommendations are provided for the material that was found to contain Asbestos Fibers within the referenced structure.

RECOMMENDATIONS

Recommended response actions have been selected for all Asbestos Containing Materials identified by this survey within the facility. Recommendations for response actions, where arrived at, are stated as follows:

FRIABLE ASBESTOS CONTAINING MATERIALS

Friable Asbestos Material means any material containing more than one (1%) percent asbestos, that when dry can be crumbled, pulverized or reduced to powder by hand pressure.

(904) 665-0100 (904) 612-1456 • MOBILE (904) 665-0101 • FAX

Friable Asbestos Material was found in the following area:

None.

The above material is considered friable and must be removed by a Certified Florida Asbestos Abatement Contractor prior to any disturbance caused by renovation or demolition of the referenced structure.

CATEGORY I, NON-FRIABLE ASBESTOS MATERIAL

None.

CATEGORY II, NON-FRIABLE ASBESTOS MATERIAL

HM-5 Transite Siding - Gray [10% Chrysotile Asbestos]

NONREGULATED BY NESHAP; REGULATED BY OSHA

None.

The preceding materials are considered a Category I or II Non-Friable Material and therefore, under normal circumstances, the Category I material does not need not be removed prior to demolition, because generally these materials do not release significant amounts of Asbestos Fibers, even when damaged.

Category I material must be kept wet to prevent the release of fibers during demolition. The Category I asbestos waste must be placed in a permitted asbestos landfill in accordance with FDEP regulations. Friable asbestos and Category II material must be removed prior to demolition or renovation of the structure. Yet, in the event removal is deemed necessary as a part of renovation all Asbestos Containing Material should be removed by a Florida Licensed Asbestos Contractor. The building materials identified in this asbestos renovation survey were in good condition to significantly damaged at the time of the inspection. The material condition can change over time and will degrade with exposure to water, air movement, physical damage, weather and chemical exposure.

The structure has an address of, 2280 Hilly Road, Jacksonville, Florida. The facility was at one time a house. The facility has one single story structure for demolition.

When implementing the response actions, parties responsible for final selection should remember that actions shall be sufficient to protect HUMAN HEALTH AND THE ENVIRONMENT, but may also be the least burdensome method. Nothing in these recommendations should be construed as PROHIBITING or discouraging removal.

All parties shall comply with all applicable laws, ordinances, rules and regulations of Federal, State and Local Governments and Agencies relating to or affecting the proposed work in whole or in part when implementing any response action associated with the facility.

The following samples are recommended to be further analyzed by the point count method using a positive stop approach.

None.

This asbestos survey shall not be used as a design or specification for the removal of asbestos within the referenced structure.

RECOMMENDATIONS FOR ASBESTOS ABATEMENT: (2280 Hilly Road, Jacksonville, Florida)

The HM-5 asbestos material must be removed prior to demolition of the structure by a licensed Florida Asbestos Abatement Contractor.

These materials are regulated by one or both of the following regulations: the Occupational Safety and Health Administration (OSHA) Construction Standard for Asbestos found in Title 29 Code of Federal Regulations (CFR) Part 1926.1101 and by the National Emission Standards for Hazardous Air Pollutants (NESHAP) Title 40 CFR Part 61.145.

It has been a pleasure working with you and I look forward to working with you once again in the future. I can be reached at (904) 665-0100 or mobile (904) 612-1456 if you should have any questions.

Respectfully submitted,

Timothy W. Rudolph, P.E., L.A.C.
Licensed Asbestos Consultant AX 0000058
Asbestos Business License ZA0000243
< MICHAEL LLOYD HAULING-ASBESTOS- SURVEY-JON-6193.doc>

10/4/2017

D710597

ROUTINE **CHAIN OF CUSTODY FORM** **JON 6193**

ENVIRONEERING, INC., 109 Azalea Point Drive South, Ponte Vedra Beach, Florida 32082

To Laboratory: Dove Environmental Laboratory
4715 NW 157th Street
Miami, Florida 33014

ROUTINE TURN AROUND TIME

Customer Information
Company Name: ENVIRONEERING, INC.
Address: 109 Azalea Point Drive South
City, State, Zip: Ponte Vedra Beach, FL 32082
Contact: Mr. Tim Rudolph

Date: 9/30/2017
Phone: (904) 665-0100
Fax: (904) 665-0101
Project: Michael Lloyd Hauling, Inc.
2280 Hilly Road
Jacksonville, FL
<COC-DOVE-6193-1>

Sample #	Sample Type	Sample Location	COLOR/AREA	F/NF
1-1	BULK	Drywall System- White	White/Ceilings/Walls	NF
2-1	BULK	Plaster Wall System - Two Coats White over Gray with Drywall Board	White/Walls/Ceiling	NF
3-1	BULK	9"X9" Vinyl Floor Tile (VFT) Red with yellow Mastic	Red/Floor	NF
4-1	BULK	Sheet Flooring - Beige (Utility Room)	Beige/Floor	NF
5-1	BULK	Tranite Siding - Gray	Gray/Wall	NF
		ENCLOSURE (1) ENVIRONEERING, Inc. Ltr Dtd 10/04/2017		
		1 - SINGLE STORY STRUCTURE		

ASBESTOS - PLM

CHAIN OF CUSTODY CHECK # 3202 Paid

Date/Time	Released by:	Date/Time	Released by:
09/30/2017 - 17:30			

DOVE ENVIRONMENTAL CORP.
8910 MIRAMAR PARKWAY, SUITE 200 MIRAMAR FL 33025
Tel. (954) 374-9274 Fax: (954) 639-7426

ASBESTOS TEST REPORT

CLIENT : ENVIRONEERING, INC.
ADDRESS: 109 AZALEA POINT DRIVE., SOUTH
PONTE VEDRA BCH FL 32082
PROJECT: JON 6193/ MICHAEL LLOYD HAULING, INC
2280 HILLY RD. JACKSONVILLE, FL
CONSULT: TIM RUDOLPH

PAGE : 1
DATE : 10/03/17
SAMPLE ID : D710597
NVLAP Lab Code: 102053-0

LAB NO. : 01
FRI/HOM : YES/NO LAYERS: 02
DESCRIPTION : DRYWALL SYSTEM-WHITE
ASBESTOS TYPE: NONE-DETECTED
OTHER FIBERS : 20% CELLULOSE
NON FIBERS : 60% MINERALS

SAMPLE NO.: 1-1
DATE OF ANALYSIS: 10/03/17
10% FIBER-GLASS
10% PAINT

LAB NO. : 02
FRI/HOM : NO/NO LAYERS: 03
DESCRIPTION : PLASTER WALL SYSTEM-TWO COATS WHITE OVER GRAY WITH DRYWALL BOARD
ASBESTOS TYPE: NONE-DETECTED
OTHER FIBERS : 20% CELLULOSE
NON FIBERS : 40% MINERALS
30% POLYMERS

SAMPLE NO.: 2-1
DATE OF ANALYSIS: 10/03/17
10% PAINT

LAB NO. : 03
FRI/HOM : NO/NO LAYERS: 02
DESCRIPTION : 9"X9" VFT RED WITH YELLOW MASTIC
ASBESTOS TYPE: NONE-DETECTED
OTHER FIBERS : 5% CELLULOSE
NON FIBERS : 60% MINERALS
5% RESINS

SAMPLE NO.: 3-1
DATE OF ANALYSIS: 10/03/17
30% POLYMERS

Dove Environmental Corporation is solely responsible for analysis performed on sample content supplied by client and is NVLAP accredited for Method 40 CFR Pt. 736, App. E to Subpart E EPA/600/R-93/116. Measurement Uncertainty information is available by contacting the Laboratory. Laboratory Reports will be kept for a period of three (3) years electronically. Percentages are visually estimated. Point count performed at clients request only. Results relates only to item analyzed. This report should not be reproduced by client or anyone without written permission from Dove Environmental Corporation. All samples will be stored for a period of 1 month. The use of the term NVLAP does not constitute endorsement by NVLAP or any agency of the United States Government. Floor-Tile is non-homogeneous and results only reflect sample content.

Analyst 1

R. Pepe Ramnath, PhD
LABORATORY MANAGER

DOVE ENVIRONMENTAL CORP.
8910 MIRAMAR PARKWAY, SUITE 200 MIRAMAR FL 33025
Tel. (954) 374-9274 Fax: (954) 639-7426

ASBESTOS TEST REPORT

CLIENT : ENVIRONEERING, INC.
ADDRESS: 109 AZALEA POINT DRIVE., SOUTH
PONTE VEDRA BCH FL 32082
PROJECT: JON 6193/ MICHAEL LLOYD HAULING,INC
2280 HILLY RD. JACKSONVILLE, FL
CONSULT: TIM RUDOLPH

PAGE : 2
DATE : 10/03/17
SAMPLE ID : D710597
NVLAP Lab Code: 102053-0

LAB NO. : 04
FRI/HOM : NO/NO LAYERS: 03
DESCRIPTION : SHEET FLOORING-BEIGE
ASBESTOS TYPE: NONE-DETECTED
OTHER FIBERS : 20% CELLULOSE
NON FIBERS : 40% MINERALS
30% POLYMERS

SAMPLE NO.: 4-1
DATE OF ANALYSIS: 10/03/17
10% RESINS

LAB NO. : 05
FRI/HOM : NO/NO LAYERS: 02
DESCRIPTION : TRANSITE SIDING-GRAY
ASBESTOS TYPE: 10% CHRYSOTILE
OTHER FIBERS : 5% CELLULOSE
NON FIBERS : 45% MINERALS
30% POLYMERS

SAMPLE NO.: 5-1
DATE OF ANALYSIS: 10/03/17
10% PAINT

Dove Environmental Corporation is solely responsible for analysis performed on sample content supplied by client and is NVLAP accredited for Method 40 CFR Pt. 736, App. E to Subpart E EPA/600/R-93/116. Measurement Uncertainty information is available by contacting the Laboratory. Laboratory Reports will be kept for a period of three (3) years electronically. Percentages are visually estimated. Point count performed at clients request only. Results relates only to item analyzed. This report should not be reproduced by client or anyone without written permision from Dove Environmental Corporation. All samples will be stored for a period of 1 month. The use of the term NVLAP does not constitute endorsement by NVLAP or any agency of the United States Government. Floor-Tile is non homogeneous and results only reflect sample content.

Analyst 1

R. Pepe Ramnath, PhD
LABORATORY MANAGER

TITLE: DEMO & SITE CLEARANCE OF 43 PROPERTIES BID NO.: CF-0110-17 (MUNICIPAL CODE)		MICHAEL LLOYD HAULING, INC.				ERS CORP.				P & G LAND CLEARING, INC			
12	**2432 EDGEWOOD AVENUE**, (MAIN AND ACCESSORY) DESCRIBED AS; 22-25 39-1S-26E MAGNOLIA GARDENS UNIT 2 LOT 4 BLK 9 (DEMOLITION AND SITE CLEARANCE) R.E. #028165-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 3,625.00	$ 3,800.00	$ 4,600.00	$ 275.00	$ 3,797.00	$ 4,072.00	$ 2,495.00	$ 275.00	$ 4,225.00	$ 4,500.00	$ 1,000.00
13	**12222 FT CAROLINE ROAD**, (SINGLE FAMILY), DESCRIBED AS; 46-1S-28E .546 R SANCHEZ GRANT PT RECD O/R 17408-446 (DEMOLITION AND SITE CLEARANCE) R.E. #160676-0140 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (GREATER ARLINGTON)	NO BID	NO BID	NO BID	NO BID			$ -		$ 475.00	$ 18,975.00	$ 19,450.00	$ 2,000.00
14	**2280 HILLY ROAD**, (SINGLE FAMILY ON EAST SIDE UNIT #A), DESCRIBED AS; 17-75 39-1S-26E RIVERHILLS PARK ADDN S/D PT LOT 9 BLK 4 (DEMOLITION AND SITE CLEARANCE) R.E. #029799-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (NORTH)	$ 175.00	$ 3,000.00	$ 3,175.00	$ 3,975.00	$ 275.00	$ 4,293.00	$ 4,568.00	$ 1,000.00	$ 275.00	$ 5,075.00	$ 5,350.00	$ 1,000.00
15	**2931 LAGNEY DRIVE**, (ACCESSORY STRUCTURE ONLY) DESCRIBED AS; 26-23 39-1S-26E RIBAULT MANOR LOT 23 BLOCK 3 (DEMOLITION AND SITE CLEARANCE) R.E. #025183-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND A WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 4,325.00	$ 4,500.00	$ 5,300.00	$ 275.00	$ 3,000.00	$ 3,275.00	$ 1,000.00	$ 275.00	$ 3,475.00	$ 3,750.00	$ 1,000.00
16	**3723 LEHIGH STREET**, (SINGLE FAMILY) DESCRIBED AS; 3-4 55-2S-26E OWENS ADDN TO JACKSONVILLE S 40FT LOT 5 BLK 6 (DEMOLITION AND SITE CLEARANCE) R.E. #086547-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND A WET DEMOLITION) (NORTH)	$ 175.00	$ 2,750.00	$ 2,925.00	$ 3,625.00	$ 275.00	$ 3,731.00	$ 4,006.00	$ 1,000.00	$ 275.00	$ 4,475.00	$ 4,750.00	$ 1,000.00
17	**4133 LORENZO COURT** (MULTI- FAMILY STRUCTURE) DESCRIBED AS; 40-52 39-1S-26E MONCRIEF ESTATES UNIT 1 LOT 3 (DEMOLITION AND SITE CLEARANCE) R.E. #030147-0414 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND A WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 5,800.00	$ 5,975.00	$ 6,975.00	$ 600.00	$ 10,498.00	$ 11,098.00	$ 5,368.00	$ 475.00	$ 7,575.00	$ 8,050.00	$ 1,500.00
18	**4170 LORENZO COURT**, (MULTI-FAMILY STRUCTURE) DESCRIBED AS; 40-52 29-1S-26E .370 MONCRIEF ESTATES UNIT 1 LOT 11 (DEMOLITION AND SITE CLEARANCE) R.E. #030147-0462 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND A WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 5,800.00	$ 5,975.00	$ 6,975.00	$ 600.00	$ 10,498.00	$ 11,098.00	$ 5,368.00	$ 475.00	$ 7,575.00	$ 8,050.00	$ 1,500.00
19	**3062 LOWELL AVENUE**, (SINGLE FAMILY) DESCRIBED AS; 3-4 17-2S-26E HARVEYS ADDN TO JAX N 106FT OF E 80FT LOT 1 BLK 3 (DEMOLITION AND SITE CLEARANCE) R.E. #058192-0000(CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 3,620.00	$ 3,795.00	$ 4,595.00	$ 275.00	$ 4,656.00	$ 4,931.00	$ 1,000.00	$ 275.00	$ 5,175.00	$ 5,450.00	$ 1,000.00
20	**1839 NORTH MAIN STREET**, (SERVICE GARAGE) DESCRIBED AS; 2-4 37-2S-26E SPRINGFIELD S 50FT OF N 150FT OF W 100FT OF LOT 1 & S 60FT OF LOT 2 BLK 52 RECD O/R 5450-607 (DEMOLITION AND SITE CLEARANCE) R.E. #071815-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (URBAN CORE)	$ 500.00	$ 14,000.00	$ 14,500.00	$ 16,000.00	$ 600.00	$ 16,250.00	$ 16,850.00	$ 1,000.00	$ 475.00	$ 17,725.00	$ 18,200.00	$ 2,000.00
21	**1277 MAYNARD STREET**, (SINGLE FAMILY) DESCRIBED AS; 13-42 39-1S-26E .25 N BROOKSIDE PT LOT 10, BLK 15 PT SEC 39 RECD O/R 14066-149 (DEMOLITION AND SITE CLEARANCE) R.E. #032576-0000 (CONTRACTOR MUST SUBMIT A BID FOR COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (NORTH)	$ 175.00	$ 5,500.00	$ 5,675.00	$ 6,575.00	$ 275.00	$ 9,808.00	$ 10,083.00	$ 1,000.00	$ 475.00	$ 8,475.00	$ 8,950.00	$ 1,500.00
22	**3627 MCMILLAN AVENUE**, (SINGLE FAMILY) DESCRIBED AS; 27-87 39-1S-26E FERN PARK LOT 13 (DEMOLITION AND SITE CLEARANCE) R.E. #027760-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 3,525.00	$ 3,700.00	$ 4,500.00	$ 275.00	$ 4,524.00	$ 4,799.00	$ 1,000.00	$ 275.00	$ 4,675.00	$ 4,950.00	$ 1,000.00
23	**3622 MCMILLAN AVENUE**, (SINGLE FAMILY) DESCRIBED AS; 28-012 39-1S-26E BUSH TERRACE LOT 7 O/R BK 3073-566 (DEMOLITION AND SITE CLEARANCE) R.E. #027769-0000 (CONTRACTOR MUST SUBMIT A BID FOR THE COST OF AN ASBESTOS SURVEY AND WET DEMOLITION) (NORTHWEST)	$ 175.00	$ 3,325.00	$ 3,500.00	$ 4,300.00	$ 275.00	$ 4,062.00	$ 4,337.00	$ 1,000.00	$ 275.00	$ 4,675.00	$ 4,950.00	$ 1,000.00

SUBJECT: **DEMO & SITE CLEARANCE OF 43 PROPERTIES**

BID# CF-0110-17 OPEN DATE: **2017-04-05**

GENERAL GOVERNMENT AWARDS COMMITTEE

KIND AND BASIS OF CONTRACT:
CONSTRUCTION FIXED

AGENCY: **NEIGHBORHOODS**

BASIS OF AWARD: **BY ITEM TO THE LOWEST RESPONSIVE, RESPONSIBLE BIDDER**

NUMBER OF BIDS INVITED 7 NUMBER RECEIVED 4 OTHER 0

SUMMARY OF BIDS AND RECOMMENDED ACTIONS:

Recommend approval of award to the lowest responsive, responsible bidder(s) as follows: Arwood, Inc., bid item 13 in the amount of $17,500.00; ERS, Corp, bid item(s): 6, 7, 9, 15, 35 and 38 in the amount of $24,280.00; Michael Lloyd Hauling, bid item(s): 1, 2, 4, 5, 11, 12, 14, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 36, 39, 40, 41 and 42 in the amount of $134,045.00 and; P & G Land Clearing, Inc., bid item(s) 8, 10 and 37 in the amount of $22,250.00. Total award amount not-to-exceed $198,075.00.

Item #3 has been complied by owner, Item #43 will not be awarded at this time.

This award to be funded by account: ERCD1N1FR-03410 to be executed by Purchase Order(s)

Attachments: Recommendation Memo, Bid Tabulation, Terms & Conditions

BUYER: Marilyn Laidler
MARILYN LAIDLER

RESPECTFULLY SUBMITTED:
GREGORY PEASE, CHIEF
PROCUREMENT DIVISION

CONCURRENCE BY: **Bryan Mosier, Chief, Municipal Code Compliance Division**

(ALL AWARD ACTIONS SUBJECT TO LAWFULLY APPROPRIATED FUNDS)

ACTION OF GGAC COMMITTEE ON RECOMMENDATIONS ABOVE

MEMBERS APPROVING 3 MEMBERS DISAPPROVING Ø DATE: 4/20/17

OTHER:

ACTION OF AWARDING AUTHORITY DATE: 4/20/17

APPROVED DISAPPROVED

OTHER

Sam E. Mousa
Chief Administrative Officer
For: Mayor Lenny Curry
Under Authority of:
Executive Order No. 2015-05

SIGNATURE OF AUTHENTICATION

FORM GB-108, Revised 12/2007

QWS3270X 12/27/2017 2:08 PM
FAML6350 V5.1 ** NW COJ FAMIS PRODUCTION ** 12/27/2017
LINK TO: ACCOUNT SUMMARY INQUIRY 2:08 PM

FISCAL MO/YEAR : 03 2018 CURRENCY CODE :
INDEX CODE : ERCC011CP CODE COMPLIANCE
SUBOBJECT : 03410 CONTRACTUAL SERVICES
PROJECT :
PROJECT DETAIL :
GRANT :
GRANT DETAIL :
USER CODE :

S	DEC 2017	ANNUAL BALANCE	ALL YEARS BALANCE
ESTIMATED REVENUES	.00	.00	.00
REVENUES	.00	.00	.00
UNREALIZED REVENUES	.00	.00	.00
BUDGET	.00	578,993.76	578,993.76
EXPENDITURES	11,940.00	11,940.00	11,940.00
ENCUMBRANCES	115,033.00	329,525.76	329,525.76
PRE-ENCUMBRANCES	.00	.00	.00
REMAINING BALANCE	-126,973.00	237,528.00	237,528.00

F1-HELP F2-SELECT F4-PRIOR F5-NEXT
F9-LINK F10-PRIOR-MO F11-NEXT-MO
G005 - PRIOR RECORD DISPLAYED